

# AS2208 Test Certificate

## TEST RESULT STATEMENT

**ORGANIC COATED GLASS TO IMPACT REQUIREMENTS OF  
AS/NZ2208: 1996 TO GRADE A STATUS**

**“SAFETY GLAZING MATERIALS IN BUILDINGS”**

**Safe Plus™ Safety & Security Films  
SEC04, SEC07, SEC08, S4(100 micron) & S7(200 micron) Film Codes.**

**Manufactured by: Johnson Laminating & Coating Inc.  
20631 Annalee Ave, Carson California 90746 USA**

**In recognition that the above range of Safe Plus™ Safety & Security  
Window Films have deemed to have passed the impact requirements of  
Australian Safety Standard AS/NZ2208: 1996 to Grade A Status  
when attached to one surface of 3mm Annealed Glass.**

**Test Report No. 2907/02 by: Jacob & Associates  
313 Canterbury Road, Canterbury NSW 2144 Australia.**

Please note that this certificate applies only to the suitability of the composite material. The use of such safety glazing material is then covered under strict guidelines contained in Australian Safety Standard AS1288. It is the installer's sole responsibility, *Duty of Care*, to ensure that this product is used in accordance with those guidelines. Johnson Professional Window Films Pty Ltd will not accept any responsibility or liability or consequential damage for the installation of Safe Plus™ window films. Copies of the relevant Australian safety standards are available from Standards Australia offices located in all major capital cities.

**Safe Plus™ Safety & Security Films** distributed by



**Johnson Professional Films  
Unit 8 / 79 Mandoon Road Girraween NSW 2145  
Phone (02) 9636 6011 Fax (02) 9636 6022**

**ABN 60 090 685 653 A division of Johnson Professional Window Films Pty Ltd ACN 090 685 653**

